Janet Napolitano
Governor

ARIZONA DEPARTMENT
OF
ENVIRONMENTAL QUALITY

1110 West Washington Street • Phoenix, Arizona 85007
(602) 771-2300 • www.azdeq.gov

Stephen A. Owens
Director

DATA REQUIRED WITH ECC

THE FOLLOWING RECORD REQUIREMENTS ARE ATTACHED:

1.0 CONSTRUCTION DRAWINGS WITH "AS-BUILT" LOCATION OF PIPE, FITTINGS, ETC. MARKING IN RED PREPARED BY___

2.0 PRESSURE AND LEAKAGE TEST RESULTS					
2.1 DATE TESTED					
2.2 TIME STARTED					
2.3 TIME FINISHED					
2.4 PIPE DIAMETER					
2.5 FOOTAGE TESTED					
2.6 ALLOWABLE LEAKAGE					
2.7 LEAKAGE OBSERVED					
2.8 PRESSURE AT TEST POINT					
2.9 EMPLOYEE OBSERVING TEST (print)					
2.10 INITIALS OF EMPLOYEE					
3.0 DISINFECTION SAMPLING:					
3.1 INTIAL SAMPLING	DATE				
(Minimum 50 ppm available chlorine)	TIME				
	PPM Cl_2				
3.2 AFTER 24 HOURS DETENTION TIME	DATE				
(Minimum 10 ppm free chlorine)	TIME				
	PPM Cl_2				
3.3 AFTER SUFFICIENT FLUSHING	DATE				
(Water is clear and system Cl_2 residual is measured)	TIME				
	PPM Cl_2				
4.0 BACTERIOROLOGICAL SAMPLING (S):	DATE				
	TIME				
	ATTACHED				
		Yes/No	Yes/No	Yes/No	Yes/No

I certify that I have inspected the work done and have found it to be satisfactory and in accordance with approved specifications.

_____ _____

Authorized Person's Signature Date

Northern Regional Office
1801 W. Rt. 66 • Suite 117 • Flagstaff, AZ 86001
(928) 779-0313

Southern Regional Office
400 West Congress Street • Suite 433 • Tucson, AZ
85701 • (520) 628-6733

Printed on recycled paper